


(EN) DHW / header temp. Sensor	(ES) Sens. de temp. ACS / colector	(TR) BW / Raylı ileri akım algılayıcısı
(DE) Brauchwasser / Schienenvorlauffühler	(CS) Snímač teploty TUV/ sběrače	(RU) BW / Общая подача Датчик
(NL) Tapwater / verdelervoeler	(SL) Toplotni senzor DHW / glavni	(HU) BW / header érzékelő
(FR) Sonde ECS / de collecteur	(DA) DHW / Fremløbs temp. Sensor	(PL) czujnik BW / Szynowy czujnik dopływu
(IT) Sonda sanitario / collettore	(EL) Αισθη. θερμοκ DHW / συλλέκτη	(RO) senzor BW / Senzor avans şine



R600 EVO




R600 EVO



1X



1X



(EN) DHW / header temp. Sensor

(DE) Brauchwasser / Schienenvorlauffühler

(NL) Tapwater / verdelervoeler

(FR) Sonde ECS / de collecteur

(IT) Sonda sanitario / collettore

(ES) Sens. de temp. ACS / colector

(CS) Snímač teploty TUV/ sběrače

(SL) Toplotni senzor DHW / glavni

(DA) DHW / Fremløbs temp. Sensor

(EL) Αισθη. θερμικ DHW / συλλέκτη



(TR) BW / Raylı iletir akım algılayıcısı

(RU) BW / Общая подача Датчик





(HU) BW / header érzékelő

(PL) czujnik BW / Szynowy czujnik dopływu

(RO) senzor BW / Senzor avans şine



Par.: N0. XXXX	Setting
5730	B3
6200	yes, ja, ja, oui, sí, sí, Ano, ja, Ja, Naí, Evet, да, Igen, tak, da




Par.: N0. XXXX	Setting
5931	B10
6200	yes, ja, ja, oui, sí, sí, Ano, ja, Ja, Naí, Evet, да, Igen, tak, da

(EN) DHW / header temp. Sensor
 (DE) Brauchwasser / Schienenvorlauffühler
 (NL) Tapwater / verdelervoeler
 (FR) Sonde ECS / de collecteur
 (IT) Sonda sanitario / collettore

(ES) Sens. de temp. ACS / colector
 (CS) Snímač teploty TUV/ sběrače
 (SL) Toplotni senzor DHW / glavni
 (DA) DHW / Fremløbs temp. Sensor
 (EL) Αισθη. θερμοκ DHW / συλλέκτη

(TR) BW / Raylı iletir akım algılayıcısı
 (RU) BW / Общая подача Датчик
 (HU) BW / header érzékelő
 (PL) czujnik BW / Szynowy czujnik dopływu
 (RO) senzor BW / Senzor avans şine



•		ESC	(2x)
•		OK	(1x)
•		Info	(4sec.)
•		“Engineer” “Fachmann” “Installateur” “Spécialiste” “Specialista” “Ingeniería” “Technik” “Odborník” “Fagmand” “Engineer” “Mühendis” “Инженер” “Tervező” “Specjalista” “Engineer”	OK (1x)
•		“Configuration” “Konfiguration” “Configuratie” “Configuration” “Configurazione” “Configuración” “Konfigurace” “Konfigurácia” “Konfiguration” “Configuration” “Konfigurasyon” “Конфигурация” “Konfiguráció” “Konfiguracja” “Configuration”	OK (1x)
•		“Par.: N0. XXXX”	OK (1x)
•		“Setting”	OK (1x)
•		ESC	(2x)
•		RESET	(1x)